

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 250

Date-08-08-25

It is certified that an inspection team headed by Mr. Kamalakanta Singha, Pradhan, Sautia Gram Panchayat from Sautia Gram Panchayat, Mohanpur, Paschim Medinipur, 721436

inspected the Ramakrishna Gyan Mandir, Vill- Nayagaon, P.O-Paroi, P.S-Mohanpur, Paschim Medinipur, 721436

on 08/08/2025 and on the basis of Water Test Report (Attached) bearing no. 192025260200008758, dated 08/08/25 of Dantan Sub-District Laboratory, PHED, Govt. Of West Bengal certified that the Ramakrishna Gyan Mandir has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05 years

Signature with Seal:.....

Name: Mr. Kamalakanta Singha

Designation: Pradhan, Sautia G.P

To


Ramakrishna Gyan Mandir


Vill -Nayagaon, P.o-Paroi, P.S-Mohanpur

Dist-paschim Medinipur. Pin-721436

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Manager
Ramakrishna Gyan Mandir
Nayagaon Paroi, Mo


Principal
Ramakrishna Gyan Mandir
Nayagaon, Paroi, Paschim Medinipur

GOVT. OF WEST BENGAL
DANTAN SUB-DISTRICT LABORATORY
PUBLIC HEALTH ENGINEERING DIRECTORATE
BHABANIPUR, DANTAN, DANTAN I, PASCHIM MEDINIPUR, 721426

Ref: 192025260200008758	TEST REPORT			Date: 08.08.2025	
District: Paschim Medinipur	P.H.E. Sub-Division :- Kharagpur	Block:- MOHANPUR		G.P:- SAUTIA VIII:- NAYAGAON	
Sample No:	0790-25-P-4	-	-	-	-
Source of sample :	*1	*2	*3	*4	*5
Name of Location:	RAMAKRISHNA GYAN MANDIR	---	---	---	---
Types of Water Source	Submersible	---	---	---	---
Date of collection:	07.08.2025				
Sample collected by:	SUBHAMOY BERA				

PARAMETER	EXPRESSED AS	STANDARD QUALITY As per IS: 10500:2012		Result					
		Desirable Limit	Permissible Limit (in absence of alternate source)	*1	*2	*3	*4	*5	
1. pH	-	6.5-8.5	No relaxation	7.55	-	-	-	-	-
2. TEMPERATURE	°C	-	-	30.7	-	-	-	-	-
3. TURBIDITY	NTU	1	5	0.10	-	-	-	-	-
4. TOTAL DISSOLVED SOLIDS	mg/lit	500 (max.)	2000 (max.)	272.5	-	-	-	-	-
5. CONDUCTIVITY	(µS/Cm)	-	-	N.D	-	-	-	-	-

CHEMICAL PARAMETER									
1. IRON	mg/lit	1.0 (max.)	No relaxation	0.010	-	-	-	-	-
2. MANGANESE	mg/lit	0.1(max.)	0.3 (max.)	0.010	-	-	-	-	-
3. RESIDUAL CHLORINE	mg/lit	0.2(max.)	1(max.)	N.D	-	-	-	-	-
4. TOTAL HARDNESS	mg/lit	200 (max.)	600 (max.)	164	-	-	-	-	-

BACTERIOLOGICAL PARAMETER									
1. TOTAL COLIFORM BACTERIA	MFT (Nos./100 ml)	Absent	Absent	0	-	-	-	-	-
2. FAECAL COLIFORM	Present/Absent	Absent	Absent	0	-	-	-	-	-

Remarks: i) From the above Chemical Test Result, it can be said that all parameters of the water samples are within the permissible limit.
ii) From the above Bacteriological Test Result it can be said that the all sample are within the permissible limit.

S. Maity
08.08.2025
CHEMIST
Dantan Sub-District Lab.
P.H. Engg Dte
Chemist & Bacteriologist
Dantan Sub-Dist. Lab PHE Dte
Govt. of West Bengal

[Signature]
Manager
Ramakrishna Gyan Mandir
Nayagaon Paroi, Mohanpur

Junior Engineer
RWS, PHE Dte
Govt. of West Bengal

[Signature]
Principal
Ramakrishna Gyan Mandir
Nayagaon, Paroi, Paschim Medinipur

Asstt. Engineer
RWS, PHE Dte
Govt. of West Bengal